

TENDER FOR DATA CENTER (# SEF/NP/12-13-021)

VENDOR EVALUATION SHEET

EVALUATION CRITERIAS	AMFCO		WATEEN		PREMIER SYSTEMS		AGCN		SCT PVT LTD	
	YES or NO	FINDINGS	YES or NO	FINDINGS	YES or NO	FINDINGS	YES or NO	FINDINGS	YES or NO	FINDINGS
QUALIFICATION CRITERIA AS PER BIDDING DOCUMENTS ITB # 13.3D										
Data Center with having strong track record (at least 3 projects of 10 Gig in last 3 years) in same projects	NO	One 10 G project (world call) One data centre (IBA)	NO	Two 10 G projects (PTCL , CITI Bank) - One Data centre (My Bank)	NO	Three Data centre(Bank Alfiah , KSE , Byco) - 10 G not mentioned	YES	3 data centre (Sindh Police , TEVTA , FBR , PITB) , PTCL , FFC , (10 points) and 3 10 G projects (Sindh Police . PTCL . FBR)	DID NOT EVALUATE	
Annual turnover atleast 30 million	YES		YES		YES		YES			
Strong cashflow (atleast 15 million	YES	Sales Figures: In 2012- Rs.271,185,900/-, in 2011- Rs.223,100,279/- & in 2010- Rs.176,695,400/-	YES	Sales Figures: In 2011- Rs.5,137,329,000/-, in 2010- Rs.3,257,190,000/-	YES	Sales Figures: In 2011- Rs.1,578,776,490/- & in 2010- Rs.1,497,913,904/-	YES	Sales Figures: In 2012- Rs.1,521,906,218/-, in 2011- Rs.1,071,942,814/- & in 2010- Rs.34,198,978/-		
BIDS ARE COMPLAINT (With deadline, Sealed and With Bid Security).	YES ALL COMPLIED.		YES ALL COMPLIED.		YES ALL COMPLIED.		YES ALL COMPLIED.		NOT COMPLIED (Because his Bid Security was found at Cross Cheaque)	

TENDER FOR DATA CENTER (# SEF/NP/12-13-021)

VENDOR EVALUATION SHEET

EVALUATION CRITERIAS	AMFCO		WATEEN		PREMIER SYSTEMS		AGCN		SCT PVT LTD	
	YES or NO	FINDINGS	YES or NO	FINDINGS	YES or NO	FINDINGS	YES or NO	FINDINGS	YES or NO	FINDINGS
Quoted Price by the Bidder in PKR.	PKR 63,102,890		PKR 64,789,653		PKR 87,194,335		PKR 64,651,139			
Findings in Arithmetic check.	No	Calculation Error for Glass Door (QTY 4) - Approx difference of 598,620 PKR. Charges for Cable tray for external use piping , drainage and running line water for humidifier not include . Lesser QTY for processer and memory quoted . Vstorage and Vcentre not quoted . Only One Sequential AC control quoted- (required QTY 2). Installation , Testing , tagging with Fluke report for Regional offices services not quoted. Only unit prices given for Pipe fitting accessories - Vcentre not quoted . Only one window server software quoted (required QTY 3)	No	Electrical UPS DB item quoted but no price given (approx price as per vendor's own rate 278,539 PKR) . Prices for medatory items (LCD and Furniture for Network Operation centre) not quoted. Only One Sqquential AC control quoted - Installation Charges for Piping , drainage and civil work for Precision unit outer is not catered in solution. Connectivity for Seven location required where only Six quoted . Vstorage and Vcentre not quoted. Unit prices Quoted for Pipe fitting accessories - Installation , Testing and tagging charges for regional offices not quoted	No	Only One wireless access point unit quoted where as required was 5	YES	No arithmetic error found	DID NOT EVALUATE	
After calculation of error, Final price of Bidder in PKR.							PKR 64,651,139			

TENDER FOR DATA CENTER (# SEF/NP/12-13-021)

VENDOR EVALUATION SHEET

EVALUATION CRITERIAS	AMFCO		WATEEN		PREMIER SYSTEMS		AGCN		SCT PVT LTD		
	YES or NO	FINDINGS	YES or NO	FINDINGS	YES or NO	FINDINGS	YES or NO	FINDINGS	YES or NO	FINDINGS	
RESPONSIVENESS TO ALL SPECIFICATIONS (of all 9 solutions).											
Solution -1 (DATA CENTER FACILITY).	NO	Installation Charges for Piping , drainage and civil work for precision cooling unit outer is not catered in solution - Quoted Data centre cabling not compliant to the specification (Quoted 24 AWG , where as in Tender the required was 23 AWG). Only One Sequential AC control quoted- Calculation Error for supply and installation of Glass Door (QTY 4) ,if unit price prevails , montery impact of 598,620 PKR Fire Suppression and Detection unit not compliant , quoted pyrogen where as required was NOVEC 1230.	NO	Prices for medatory items (LCD and Furniture for Network Operation centre) not quoted - Fire Suppression and Detection unit not compliant , quoted pyrogen where as required was NOVEC 1230 - Mendatory Items (Electrical DB for UPS and Racks) not quoted - Only One Sequential AC control quoted - Installation Charges for Piping , drainage and civil work for Precision unit outer is not catered in solution	Yes	Fully Complied	Yes	Fully Complied	DID NOT EVALUATE		
Solution -2 (COMPUTING PLATFORMS).	NO	Quoted one processor per blade server (3) where as dual (6) was required. Same as less memory quoted - 18 quoted where as it should be 24 in given scenario	Yes	Fully Complied	Yes	Fully Complied	Yes	Fully Complied			
Solution -3 (SOFTWARE SOLUTION).	NO	Window Server 2012 , Only one quoted where it should be 3 as per specification. Vstorage not quoted	NO	Vcentre and Vstorage not Quoted	Yes	Fully Complied	Yes	Fully Complied			
Solution -4 (STORAGE SOLUTION).	NO	RAW capacity Not compliant, Maximum supported 180TB . Required RAW capacity Not compliant, required 18x900GB or 23x600GB	Yes	Fully Complied	NO	Flash memory not complied	Yes	Fully Complied			
Solution -5 (NETWORK EQUIPMENTS).	YES	Fully Complied	Yes	Fully Complied	Yes	Fully Complied	Yes	Fully Complied			
Solution -6 (NETWORK CONNECTIVITY SOLUTION).	Yes	Fully Complied	No	Connectivity for Seven location required where only Six quoted	NO	Only One API quoted whereas required QTY was 5	Yes	Fully Complied			
Solution -7 (TRAINING SOLUTION).	Yes	Fully Complied	Yes	Fully Complied	Yes	Fully Complied	Yes	Fully Complied			

SINDH EDUCATION FOUNDATION

PROGRAM: PPRS

Bid Opening Date: March 5, 2015

TENDER FOR DATA CENTER (# SEF/NP/12-13-021)

VENDOR EVALUATION SHEET

EVALUATION CRITERIAS	AMFCO		WATEEN		PREMIER SYSTEMS		AGCN		SCT PVT LTD	
	YES or NO	FINDINGS	YES or NO	FINDINGS	YES or NO	FINDINGS	YES or NO	FINDINGS	YES or NO	FINDINGS
Solution -8 (INFRASTRUCTURE CABLING SOLUTION).	No	Quoted Cable not compliant - 24 AWG quoted instead of 23 AWG . Installation , Testing , tagging with Fluke report for Regional offices services not quoted. Only unit prices given for Pipe fitting accessories	NO	16 core Fiber Core was mandatory requirement whereas Vendor quoted for 6 core --- Unit prices Quoted for Pipe fitting accessories installation , Testing and tagging charges for regional offices not quoted	Yes	Fully Complied	Yes	Fully Complied		
Solution -9 (ACCOUNT MAINTENANCE SERVICES).	Yes	Fully Complied	Yes	Fully Complied	Yes	Fully Complied	Yes	Fully Complied		

On the basis of above evaluation, M/s. AGCN has recommended for onward process.